




Orencia Systems Incorporated

18", 24", and 30" PUMP BASIN





Pump Basin

- Basin Diameter _____
- Basin Top Elevation _____
- Basin Bottom Elevation _____
- Inlet Invert Elevation _____
- Outlet Invert Elevation _____
- Discharge Pipe Size _____
- Check Valve (Y/N) _____
- Dose Volume _____

Pump Description

- Make _____
- Model _____
- GPM @ TDH _____
- HP _____
- Voltage/Phase _____
- Discharge Size _____



Pump Basin

18" Diameter - 1.06 gal/in (12.7 gal/Ft)

- PB 1848 MSC 18" X 48"
- PB 1860 MSC 18" X 60"
- PB 1872 MSC 18" X 72"

24" Diameter - 1.88 gal/in (22.5 gal/Ft)

- PB 2448 MSC 24" X 48"
- PB 2460 MSC 24" X 60"
- PB 2472 MSC 24" X 72"

30" Diameter - 2.96 gal/in (35.52 gal/Ft)

- PB 3048 MSC 30" X 48"
- PB 3060 MSC 30" X 60"
- PB 3072 MSC 30" X 72"

Standard sizes listed

Note: Custom Pump

Vaults Available

DRAWN	jdu
SCALE	
DATE	12/20/04
APPROVED	

7125 East Pickard Road
P. O. Box 309
Mt. Pleasant, MI 48804-0309
ph-989-773-9938
fax-989-772-3415



NO	REVISION	DATE	BY
1	12/04		jdu
2	6/08		SLB
3			
4			
5			

18,24,30 Pump Basin

DRAWING NO.

B3